

Annual Drinking Water Quality Report
Epping Forest Water Works
May 2009
Public Water System Identification No. 0020011

We are pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water. Our water source for 2008 was ground water from two wells, Well 2 and Well 3, both drilled into the Magothy Aquifer and located at the west edge of the community clubhouse parking area. Well 2 was drilled in May, 1973 and is approximately 95 feet deep; it is nearest to the clubhouse. Well 3 was drilled in January, 2002 and is approximately 100 feet south of Well 2; it is 198 feet deep and has the same pumping rate as Well 2. Our main source of water for calendar year 2008 was Well 3. The Well 3 water has less dissolved iron as compared to Well 2 water, rendering its treatment less complex.

In January, 2004, we were informed that the Maryland Department of the Environment's Water Supply Program (WSP) had conducted a Source Water Assessment for twenty-four community water systems in Anne Arundel County, including the Epping Forest water system. The assessment included 1) delineation of an area that contributes water to each source, 2) identification of potential sources of contamination within the areas, and 3) determination of the susceptibility of each water supply to contamination.

The water supply sources of the twenty-four community systems in Anne Arundel County are naturally protected confined aquifers of the Atlantic Coastal Plain physiographic province. The Epping Forest water system is currently using two wells that pump water from the Magothy Formation. Potential point sources of contamination were researched and identified by WSP within the assessment areas from field inspections and contaminant and well inventory databases. Well information and water quality data were also reviewed.

The susceptibility analysis was based on a review of the existing water quality data for each water system, the presence of potential sources of contamination in the individual assessment areas, well integrity, and aquifer characteristics. It was determined by WSP that the Epping Forest water supply is not susceptible to radionuclides, volatile organic compounds, synthetic organic compounds, or microbiologic contaminants originating at the land surface due to the protected nature of confined aquifers. The water supply may be susceptible to naturally occurring iron.

We are pleased to report that our drinking water is safe and meets Federal and State requirements.

If you have any questions about this report or concerning your water utility, please contact Brad Mudd, Water Works Chairman (410) 849-2296, James Goodman, (410) 849-8439, or Mike Lytle, (410) 849-8116. We want our valued customers to be informed about their water utility.

As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

Epping Forest Water Works routinely monitors for over 100 potential contaminants in your drinking water according to Federal and State laws. The table below shows the results of this testing for the period of January 1 to December 31, 2008. All contaminants that were present in your drinking water at levels detectable by laboratory equipment are shown in the table, along with two that were not detectable, lead and haloacetic acids. Some of the data, though representative, is more than a year old. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - not detectable at testing limit.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l) - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr) - measure of radiation absorbed by the body.

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level Goal - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

N/A - Not Applicable

TEST RESULTS							
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Sample Date	Likely Source of Contamination
Radioactive Contaminants							
Beta particles and photon emitters	N	3	pCi/l	0	50	3/08	Decay of natural and man-made deposits of certain minerals that are radioactive and may emit forms of radiation known as photons and beta radiation.
Alpha particles	N	1	pCi/l	0	15	3/08	Erosion of natural deposits of certain minerals that are radioactive and may emit a form of radiation known as alpha radiation.
Inorganic Contaminants							
Copper	N	0.24	ppm	1.3	AL=1.3	12/06	Corrosion of household plumbing systems, erosion of natural deposits
Lead	N	Less than 5	ppb	0	AL=15	12/06	Corrosion of household plumbing systems, erosion of natural deposits
Disinfection By-Products							
Total Trihalomethanes	N	3.09	ppm	N/A	80	5/07	Byproducts of drinking water disinfection.
Bromoform	N	3.2	ppb	0	N/A	3/02	Byproduct of drinking water disinfection.
Chloroform	N	1.2	ppb	70	N/A	3/08	Byproduct of drinking water disinfection.
Bromodichloromethane	N	1.4	ppb	0	N/A	3/08	Byproduct of drinking water disinfection.
Dibromochloromethane	N	1.4	ppb	60	N/A	3/08	Byproduct of drinking water disinfection.
Halooacetic Acids	N	0	ppm	N/A	60	5/07	Byproducts of drinking water disinfection.
Organic Contaminants							
Di(2-ethylhexyl) phthalate	N	0.9	ppb	0	6	5/05	Discharge from rubber and chemical factories

Radioactive Contaminants:

Beta/photon emitters. Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Alpha emitters. Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Inorganic Contaminants:

Copper. Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Lead. Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Disinfection By-Products:

Total Trihalomethanes [TTHMS]. Total trihalomethanes are measured as the sum concentration of chloroform, bromoform, bromodichloromethane, and dibromochloromethane. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

Haloacetic Acids [HAA5]. Some people who drink water containing haloacetic acids in excess of EPA's standard over many years may have an increased risk of getting cancer.

Organic Contaminants:

Di(2-ethylhexyl) phthalate. Some people who drink water containing di(2-ethylhexyl) phthalate in excess of the MCL over many years may have problems with their liver, or experience reproductive difficulties, and may have an increased risk of getting cancer.

As you can see by the table, our water system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring

and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead in Drinking Water: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Epping Forest Water Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Thank you for allowing us to continue providing your family with clean, quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for understanding.

Please call us if you have questions.